

Minimum Isolation Distances:

****these distances apply to your property
and any adjoining property**

Septic Tank/Aeration Unit to

well -----50 feet
water line (pressure)-----10 feet
body of water-----25 feet
dwelling -----5 feet
property line-----5 feet

Subsurface Seepage Field to

well-----75 feet
water line (pressure)-----25 feet
body of water-----25 feet
dwelling-----10 feet
property line-----5 feet
field drain tile-----10 feet

Sandfilter to

well -----75 feet
water line (pressure)-----25 feet
body of water -----15 feet
property line -----5 feet
field drain tile -----10 feet

Surface Discharge Effluent Line to

well-----50 feet
property line-----30 feet

For more information contact:

Sanitarian/Emergency Planner:

**Krista Mulholland,
618-826-5007 x 103
kmulholland@live.com**

**Administrator/
Director of Environmental
Health:**

**Tom Smith,
618-826-5007 x 120
tsmith1734@hotmail.com**

Sewage Permit Fee

Holding Tank -----\$100.00

Repair of Existing System -----\$100.00

New Home (Residential)-----\$150.00

Commercial Property-----\$175.00

Community Systems

installed in one phase-----\$200.00

installed in phases-----

\$200 plus \$40 per phase over one

RANDOLPH COUNTY HEALTH DEPARTMENT

Choosing the right Private Sewage Disposal System

2010

